

**SQAD-6 Quality Control Notices (QCN)**

**Sub Code: CRBS**

**Code reconciliation to be performed by the supplier**

Each item for which this quality statement is specified requires certification to the edition of the ASME III Boiler and Pressure Vessel Code specified in the Purchase Order. Any deviation from the specified code edition requires code reconciliation by the supplier. Later NRC approved ASME Code, Section III Editions and Addenda (complying with 10CFR50.55a) may be utilized, provided the responsible N-Certificate holder performs a reconciliation for design, materials, fabrication, examination, and testing, as prescribed by NCA-1000 and NCA-3000. The supplier shall provide Exelon with a statement of code reconciliation, if required..