

SQAD-6 Quality Control Notice (QCN)

Sub Code: HXTC

Copper-alloy Heat Exchanger Tube Cleanliness Testing

Any copper-alloy tubes for which this quality statement is specified shall receive a Cleanliness Test in accordance with section 18.2.4 of the latest revision of ASTM Specification B280. The number of tubes tested shall be in accordance with Table 8 of ASTM B280. Test results shall report the actual test residue weight in g/ft² or g/m².