

SQAD-6 Quality Control Notice (QCN)

Sub Code: HYDS

Hydrostatic test report

Each item ordered for which this quality statement is specified requires a certification of hydrostatic test. This certification, as a minimum, shall indicate the test result and the test pressure and hold time; or otherwise as specified by the Exelon PO/Contract, specification, and/or Code requirements. For pipe, only the hydrostatic test result is required and may be included in the "Certified Material Test Report" furnished. Upon completion of testing, item should be verified dry and packaged to prevent the entrance of moisture.